



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501.

January 24, 2020

Addendum 1

RFP # 20-02-207886

Wasilla Shops HVAC Upgrades

Addendum number 1 is issued for questions / clarifications.

**The Closing Date for this has not changed. This RFP will close as follows:
Proposals will be received until February 6, 2020 @ 3:00 PM local Alaska time.**

Clarifications / Questions (From April 22, 2019)

- 1) Please clarify the duct on the first floor? **It is to be painted black.**
- 2) Please provide details for concrete pads for the condenser and HX1. **Heat exchanger slab on grade pinned to existing steel mesh reinforcement. Condenser 6" slab on grade, steel mesh reinforcement.**
- 3) Who manufacture of the roofing materials? **Malarkey is the manufacturer.**

Clarifications / Questions (From January 23, 2020)

- 4) What is the thickness of the exterior walls? **The answer is 8".**

All other terms and conditions remain unchanged.

If there are any questions regarding this addendum please let me know.

Thank you,

Nori Pieknik
Contract Administrator
Alaska Railroad Corporation