

CONTRACT ISSUE

GENERAL NOTES:

1. ALL DESIGN, DETAILING, & PLACEMENT OF REINFORCING STEEL TO FOLLOW THE GUIDE LINES & STANDARDS OF THE "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE" BY THE AMERICAN CONCRETE INSTITUTE & "MANUAL OF STANDARD PRACTICE" BY THE CONCRETE REINFORCING STEEL INSTITUTE.
2. ALL CONCRETE TO HAVE MINIMUM 4000 P.S.I. COMPRESSIVE STRENGTH IN 28 DAYS.
3. ALL REINFORCING STEEL TO BE A615 GRADE 60 DEFORMED REINFORCING STEEL.
4. MINIMUM LAP: #6 BAR - 3'-0
5. ALL LAPS TO BE STAGGERED.
6. DO NOT ALLOW REINFORCING STEEL TO PUNCTURE WATERSTOP. BEND REBAR TO CLEAR WATERSTOP WHERE NECESSARY.
7. REFER TO DWG. C1 FOR GENERAL CONCRETE NOTES.

REVISED

8	DATE		4	DATE 10-12-82	CHANGED LOCATION OF SUMP
7	DATE		3	DATE 7-15-82	GENERAL REVISIONS
6	DATE		2	DATE 9-1-81	GENERAL REVISION
5	DATE		1	DATE 7-2-81	ORIGINAL ISSUE

STATE OF ALASKA 49TH W. D. MACKINSON No. C5686 REGISTERED PROFESSIONAL ENGINEER

DATE 6-25-81
SCALE NOTED
DRAWN BY D.F.
CHK'D BY EAM
APP'D BY ANH
PRINTED OCT 12 1982

PLAN & SECTION - TRACK RECEIVING - FOUNDATION REINFORCING

GRAIN EXPORT TERMINAL
STATE OF ALASKA
SEWARD, ALASKA
KIBCOR ENGINEERING COMPANY
Minneapolis, Minnesota

PLAN 3052 REVISION 4
SHEET C13

3650-09