



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501.

March 20, 2020

Addendum 1

ITB # 20-13-207520

BUILDING 26 INDUSTRIAL WATER UPGRADES

Addendum number 1 is issued for questions, clarifications and deadline extensions

This ITB will close as follows:

Proposals will be received until Wednesday, April 15, 2020 @ 3:00 PM local Alaska time.

Questions:

1. Can we schedule a second walkthrough? *Yes, we are able to accommodate a second site visit based on interest and availability while keeping consideration of mandates related to the virus.*
2. Can we push the bid date to around April 10th? *Yes, we have extended the closing date to April 15, 2020 @ 3:00 pm.*
3. Can we push the completion date a month – to October 15th? *Due to the closures and delays caused by the virus mitigation, we will push the completion date to October 16, 2020.*
4. Can we allow the use of press style copper fittings? This will allow the work to be completed in a safer manner, eliminating hot work in high elevations and in utility chases. *Yes, the use of press style copper fittings is authorized.*
5. Are there any Union requirements? *There are not union requirements for this project.*
6. Is there a specific start date? *Commencement date will be discussed at the time of award.*
7. What is the estimated Square footage of the building? *Building 26 is approx. 70,000 sqft.*

All other terms and conditions remain unchanged.

If there are any questions regarding this addendum please let me know.

Thank you,

Candice Humphrey
Procurement Administrator
Alaska Railroad Corporation