



ALASKA RAILROAD CORPORATION

327 W. Ship Creek Ave.

Anchorage, AK 99501

wallaces@akrr.com

Phone (907)265-2425

Cell (907)744-0031

ADDENDUM NO. 2

Invitation to Bid (ITB) 26-17-214505

Whittier Yard Drain Repairs Phase 1 Construction


Alaska Railroad Corporation

Date: May 13, 2026

This Addendum is issued to provide clarification in response to bidder questions. All other terms and conditions of the referenced solicitation remain unchanged.

QUESTION AND ANSWERS:

1. Can Is the 58' long section of 60" steel casing shown below intended to be one piece? If not, are there specifications/procedures for joining multiple pieces of 60" steel casing via welding or other approved methods?



Yes, the intent is for it to be one piece. The pipe may be joined by welding, unless alternative equivalent method is submitted by the contractor and approved by ARRC, prior to implementation.

Please acknowledge receipt of this and all addenda in your firms Supply Bid Form (Form 395-0129).

Sincerely,

Sarah B. Wallace

Contract Administration Specialist

Alaska Railroad Corporation