



Alaska Railroad Corporation
327 W. Ship Creek Ave.
Anchorage, AK 99501

June 11, 2024

Addendum 3

ITB #24-36-212082

Fiber Optic Cable Installation: Bear Valley

Addendum number 3 has been issued for an additional Question.

The Closing Date for this ITB has not changed.
Bids will be received until June 13, 2024 @ 3:00 PM Alaska time.

Questions:

- 1) Bear Valley project Sheet C5 to C11 shows to trench through the train tunnel. Can you verify that we are hanging a duct on the tunnel wall or if we are trenching?
The duct will be hung on an existing duct on the Tunnel wall. No trenching will take place in the Tunnel.

Please acknowledge receipt of this and all addendums in your firm's Supply Bid Form and use the updated Schedule of Values when submitting your bid.
All other terms and conditions remain unchanged.
If there are any questions regarding this addendum please let me know.

Thank you,

Greg C Goemer
Sr. Contract Administrator
Alaska Railroad Corporation